

Report to the Commission on Chicago Landmarks

March, 2022

Report to the Commission on Chicago Landmarks

Total: 160

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
12/28/2021	2/18/2022	2022-0258	600 E. Grand	100953422	Navy Pier	42	Exterior and Interior	Exterior and Interior: INTERIOR ALTERATIONS OF EXISTING FULL SERVICE RESTAURANT AS PER stamped Historic Preservation plans dated 3/1/22. No work to masonry. Outdoor bar to be held off of south elevation at least 4" from the base.		3/1/2022
3/1/2022		2022-0259	1006 S. Michigan	100952457	Historic Michigan Boulevard District	4	Exterior	Exterior: BUILDING LOCATED IN ZONING DISTRICT PD-1323.T-MOBILE'S (EXISTING CARRIER) EQUIPMENT LOCATED ON THE ROOFTOP OF A BUILDING LOCATED AT 1006 S MICHIGAN AVE, CHICAGO IS PROPOSED FOR RENOVATION. per plans dated 11/05/21. New antennas to be mounted no higher than existing and should be painted to match surrounding masonry when applicable.		3/1/2022
3/1/2022		2022-0260	210 S. Canal	100960209	Union Station	42	Miscellaneous	Misc: monthly maintenance		3/1/2022
3/1/2022		2022-0261	210 S. Canal	100956089	Union Park Hotel	42	Miscellaneous	Misc: monthly maintenance		3/1/2022
3/1/2022		2022-0262	210 S. Canal	100953477	Union Station	42	Miscellaneous	Misc: monthly maintenance		3/1/2022
3/1/2022		2022-0263	210 S. Canal	100949936	Union Station	42	Miscellaneous	Misc: monthly maintenance		3/1/2022
3/1/2022		2022-0264	104 S. Michigan	100960600	Historic Michigan Boulevard District	42	Mechanical	Electrical: SECURITY SYSTEM WORK CUSU220228A - 54249 TAWANI ENTERPRISES CARD READER 134 No other work.		3/1/2022
3/2/2022		2022-0265	3009 W. Logan	100959964	Logan Square Boulevards District	30	Exterior	Exterior: ROOF RECOVER ONLY - NO STRUCTURAL WORK:2 TILE ROOFS-REMOVE/REPLACE 30LF OF ROTTED WOOD, ICE & WATER SHIELD, 16OZ COPPER DRIP EDGE, WALL FLASHINGS, SECURE TILES WITH COPPER NAILS. REPLACE ALL THE TARRED AND BROKEN TILES. INTACT TILES TO BE REINSTALLED. Historic clay tiles to be salvaged and reinstalled as much as possible. Any new tiles required shall match historic in color, size, finish, and profile.		3/2/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
12/1/2021	2/16/2022	2022-0266	4924 S. Woodlawn	100948514	Kenwood	4	Exterior and Interior	Exterior and Interior: SELF-CERT 2019 CBRC: RESTORATION AND RENOVATION OF EXISTING 3-STORY SINGLE FAMILY RESIDENCE INCLUDING BASEMENT UNDERPINNING AND REAR ADDITION (TYPE VA) SITE WORK INCLUDES NEW TRELIS, RAISED HARDSCAPE, RECESSED AREA WELL, AND NEW IN-GROUND POOL AND SPA. NEW FRONT GATE per stamped Historic Preservation plans dated 3/2/22. No work to coach house with this approval. New addition masonry to match historic in size, color, texture, and general appearance. New mortar to match historic in color, texture, strength/type, and profile.		3/2/2022
3/2/2022		2022-0267	2333 S. Michigan	100960435	Motor Row District	3	Miscellaneous	Misc: change of contractor		3/2/2022
3/2/2022		2022-0268	720 S. Michigan	100960850	Historic Michigan Boulevard District	4	Miscellaneous	Misc: Replace The Compensation Ropes On One (1) 3000lb.cap, 30 Floors, 600 FPM, Gearless Traction Service Elevator #21. Pursuant To The Scope Of Work Submitted.EV004344		3/2/2022
3/2/2022		2022-0269	720 S. Michigan	100960852	Historic Michigan Boulevard District	4	Miscellaneous	Misc: Replace Floor Platform On One (1) 20,000lb.cap, 3-Floor, 50 FPM, Hydraulic Freight Elevator #25. Work TO Be Performed By Others Pursuant To The Scope Of Work Submitted. EV004344		3/2/2022
3/2/2022		2022-0270	175 N. State	100960622	Chicago Theater	42	Miscellaneous	Misc: monthly maintenance		3/2/2022
3/2/2022		2022-0271	301 S. Columbus	100960708	Buckingham Fountain	42	Miscellaneous	Misc: ERECTION STARTS: 3/12/2022, ERECTION ENDS: 3/12/2022. SELF CERT. 2022 ST PATRICK PARADE STAGE. 1-24X20 SL-100 MOBILE STAGE WITH WINGS. CHICAGO SPECIAL EVENTS MANAGEMENT.		3/2/2022
1/18/2022	2/15/2022	2022-0272	410 S. Michigan	100952482	Fine Arts Building	42	Interior	Interior: DDS 2019 CBRC: INTERIOR ALTERATIONS TO 3RD FLOOR THEATRE OFFICE FOR A NEW SOUNDBOOTH, EXECUTIVE LOUNGE, OFFICES AND RESTROOM AT EXISTING LIVE THEATER PORTION OF AN EXISTING OFFICE BUILDING AS PER PLANS. OCCUPANCY B -BUSINESS. CONSTRUCTION CLASS 1A. CONSULTANT REVIEWER: GLOBETROTTERS ENGINEERING Per the Historic Preservation stamped drawing dated 3/2/22. No work to the Michigan Avenue facade, public lobbies, stair halls, elevator halls, stairways and the Venetian Court with this approval.		3/2/2022
3/2/2022		2022-0273	815 W. 63rd	100960844	Chicago City Bank and Trust Co. Buildin n	20	Mechanical	Electrical: FURNISH AND INSTALL A NEW 150AMP, 240V 3PH, 3W LINE FROM THE ELECTRICAL CLOSET TO THE ELEVATOR CONTROL PANEL No other work.		3/2/2022
3/2/2022		2022-0275	600 E. Grand	100960676	Navy Pier	42	Mechanical	Electrical: ELECTRICAL MAINTENANCE PERMIT MARCH 2022 No other work.		3/2/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/2/2022		2022-0276	1 N. LaSalle	100960855	One North LaSalle Building	42	Mechanical	Electrical: INSTALL (5) DATA LOCATIONS TWO CATEGORY 6 PER LOCATION. No other work.		3/2/2022
3/2/2022		2022-0277	600 W. Chicago	100960542	Montgomery Ward	27	Mechanical	Electrical: MONTHLY ELECTRICAL MAINTENANCE PERMIT No other work.		3/2/2022
3/2/2022		2022-0278	209 S. LaSalle	100960543	Rookery Building	42	Mechanical	Electrical: MONTHLY ELECTRICAL MAINTENANCE PERMIT No other work.		3/2/2022
3/2/2022		2022-0279	400 N. Michigan	100960584	Wrigley Building	42	Mechanical	Electrical: MONTHLY ELECTRICAL MAINTENANCE MARCH 2022 522-2028-6000 No other work.		3/2/2022
3/2/2022		2022-0280	410 N. Michigan	100960587	Wrigley Building	42	Mechanical	Electrical: MONTHLY ELECTRICAL MAINTENANCE MARCH 2022 522-2028-6000 No other work.		3/2/2022
3/2/2022		2022-0281	1936 S. Michigan	100960891	Second Presbyterian Church	3	Mechanical	Electrical: 2ND PRESBYTERIAN CHURCH - 130-41265-11 - LOW VOLTAGE PERMIT FOR LOW VOLTAGE NON REQUIRED FIRE ALARM INSTALLATION No other work.		3/2/2022
12/6/2021	2/16/2022	2022-0282	2122 W. Schiller	100950087	Wicker Park District	1	Exterior	Interior and Exterior: SPR 2019 CBRC: RENOVATION OF EXISTING FIRST FLOOR UNIT IN THREE-FLAT APARTMENT BUILDING,, INTERIOR ALTERATIONS OF BASEMENT TO BE DUPLEXED WITH 1ST FLOOR UNIT AND EXCAVATED AS PER PLANS OCCUPANCY GROUP R-5, TYPE III-B CONSTRUCTION, RT-4 ZONING.(NO CHANGE TO EXISTING USE/OCCUPANCY TYPES). NO WORK TO FRONT ELEVATION.		3/3/2022
2/16/2022		2022-0283	2545 W. Logan	100944624	Logan Square Boulevards District	30	Interior	Interior: 2019 SPR: INTERIOR ALTERATIONS INCLUDING MEP WORK, FOR EXISTING 2 STORY FRAME SINGLE FAMILY RESIDENCE (R-5 OCCUPANCY) WITH BASEMENT. No exterior work or window replacement to front elevation.		3/3/2022
11/15/2021	2/16/2022	2022-0284	5001 S. Greenwood	100948248	Kenwood	4	Exterior and Interior	Exterior and Interior: Per the Historic Preservation stamped drawings dated 3/3/22. No work or alterations to the existing windows. New trim below 3rd floor window on north elevation to match the surrounding trim in material, size, profile, color and finish. When removing existing brick, in the areas indicated on the drawings only, care shall be taken to not overcut and damage the surrounding brick. As proposed, the new deck at the rear shall be no wider than the main house.		3/3/2022
3/4/2022		2022-0285	410 S. Michigan	100960767	Fine Arts Building	42	Miscellaneous	Misc: Modernization of One(1) 2500LB Capacity, 11-Floor(9 stop), Traction, Freight Elevator, pursuant to the scope of work submitted.(EV004333)		3/4/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/4/2022		2022-0286	1 N. Lasalle	100960951	One North LaSalle Building	42	Miscellaneous	Misc: **FIRE ALARM PERMIT**TENANT BUILDOUT TO AN EXISTING APPROVED CITY OF CHICAGO HIGH RISE FIRE ALARM / VOICE EVACUATION SYSTEM ON THE 24TH FLOOR. ELEVATOR RECALL IS EXISTING AND NOT PART OF THIS SCOPE		3/4/2022
3/4/2022		2022-0287	1060 W. Addison	100961026	Wrigley Field	44	Miscellaneous	Misc: monthly maintenance		3/4/2022
3/4/2022		2022-0288	141 W. Jackson	100959350	Chicago Board of Trade Building	42	Miscellaneous	Misc: monthly maintenance		3/4/2022
3/4/2022		2022-0289	1006 S. Michigan	100958401	Historic Michigan Boulevard District	4	Miscellaneous	Misc: REMOVE WIRING FROM EXISTING SPRINT CELLULAR EQUIPMENT AND REWORK CONDUIT AND WIRING FOR NEW T-MOBILE CELLULAR EQUIPMENT ON EXISTING CELLULAR SITE ROOFTOP		3/4/2022
12/21/2021	2/18/2022	2022-0290	1106 N. Hoyne	100944776	Ukrainian Village District	2	Exterior and Interior	Exterior and Interior: SC 2019 CBRC: PROPOSED REAR 2 CAR GARAGE W/ROOF DECK, REAR STEEL STAIRS, ROOF SKYLIGHT, DECONVERSION OF EXISTING 2 STORY/2 UNIT BUILDING W/BASEMENT TO SFR, PER PLANS. Per the Historic Preservation stamped drawings dated 3/4/22. If after the removal of the existing wood porch, scarring or materials such as common brick that would indicate that this wall area was not meant to be left exposed, the architect is to contact Historic Preservation staff to determine a compatible porch replacement.		3/4/2022
3/4/2022		2022-0291	50 W. Washington	100961035	Richard J. Daley Center	42	Miscellaneous	Misc.: PERMIT EXPIRES ON 05/04/2022 ERECTION STARTS: 3/20/2022, ERECTION ENDS: 5/20/2022. TENT- REINSTATE 100949112- SELF-CERT, 60 DAY EVENT (3/20/2022-5/20/2022) MBRES ERECT ONE (1) 10X50 FRAME CANOPY ALREADY UP 3/20/2022- REMOVE 05/20/2022ASSEMBLY No other work.		3/4/2022
3/4/2022		2022-0292	8 S. Michigan	100961113	Historic Michigan Boulevard District	42	Miscellaneous	Misc.: ERECT FOUR (4) SCAFFOLDS DATES 03/04/2022 THROUGH 03/04/2023 No other work.		3/4/2022
3/4/2022		2022-0293	1 N. State	100961121	Jewelers Row District	42		Electrical: LOW VOLTAGE A/V INSTALLATION ON 7TH FLOOR FOR CHICAGO COMMUNITY TRUST. No other work.		3/4/2022
3/4/2022		2022-0294	433 W. Van Buren	100959527	Old Chicago Main Post Office Building	25	Mechanical	Electrical: **FIRE ALARM PERMIT** ** FIRE ALARM PERMIT ** INSTALLATION OF ELECTROMAGNETIC LOCKING DEVICES PER CBC SECTIONS 10(13-160-269) AND 10(13-160-260) ON FLOOR 10. No other work.		3/4/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/4/2022		2022-0295	1531 N. Damen	100960899	Wicker Park District	1	Miscellaneous	Misc.: PERMIT EXPIRES ON 05/08/2022 ERECTION STARTS: 3/1/2022, ERECTION ENDS: 5/1/2022. TENT-REINSTATE 100945885- SELF- CERT 60 DAY EVENT (03/1/2022-05/1/2022) ONE OFF HOSPITALITY BIG STAR ERECT ONE (1) 20X50 (6MX15M) STRUCTURE TENT. ERECT 03/1/2021- REMOVE 05/1/2022ASSEMBLY No other work.		3/4/2022
3/8/2022		2022-0296	932 W. Randolph	100954526	Fulton-Randolph Market District	27	Sign	Sign: INSTALL A SIGN READING LULULEMON & LOGO per stamped exhibit dated 3/8/22		3/8/2022
3/8/2022		2022-0297	932 W. Randolph	100954525	Fulton-Randolph Market District	27	Sign	Sign: INSTALL A SIGN READING LULULEMON & LOGO per stamped exhibit dated 3/8/22.		3/8/2022
3/8/2022		2022-0298	932 W. Randolph	100954523	Fulton-Randolph Market District	27	Sign	Sign: INSTALL A SIGN READING LULULEMON & LOGO per stamped exhibit dated 3/8/22.		3/8/2022
3/8/2022		2022-0299	1 S. State	100961544	Carson Pirie Scott Building	42	Miscellaneous	Misc: low voltage on 7th floor		3/8/2022
3/8/2022		2022-0300	4714 N. Broadway	100961421	Uptown Square District	46	Mechanical	Electrical: REMOVING AND REPLACING APPROXIMATELY 6 CAT5E DATA CABLES. INSTALLING NEW OR EXISTING RT EQUIPMENT/CONFIGURE DISPLAYS, PRINTERS, AND CASH DRAWERS FOR THE T-MOBILE STORE. No other work.		3/8/2022
3/8/2022		2022-0301	1660 N. Hudson	100959477	Old Town Triangle District	43	Mechanical	Electrical: GFCI REPLACEMENT #2C No other work.		3/8/2022
3/9/2022		2022-0302	36 S. Wabash	100959287	Jewelers Row District	42	Miscellaneous	Misc: **FIRE ALARM PERMIT**TENANT BUILD OUT ON THE 7TH FLOOR IN AN EXISTING HIGH RISE BUILDING.		3/9/2022
3/9/2022		2022-0303	318 N. Carpenter	100958651	Fulton-Randolph Market District	27	Miscellaneous	Misc: **FIRE ALARM PERMIT**ALTERATIONS TO THE 2ND FLOOR IN AN EXISTING HIGH RISE BUILDING.		3/9/2022
2/22/2022		2022-0304	330 N. Wabash	100957537	IBM Building	42	Interior	Interior: SELF-CERT 2019 CBRC: INTERIOR TENANT IMPROVEMENTS TO EXISTING 14TH AND 19TH OFFICE FLOORS AS PER PLANS. WORK INCLUDES SELECTIVE DEMOLITION AND INTERIOR CONSTRUCTION OF NEW PARTITIONS, DOORS AND HARDWARE, POWER AND COMMUNICATION OUTLETS, CEILINGS, LIGHTING, FINISHES, MECHANICAL, ELECTRICAL, AND PLUMBING WORK. NO STRUCTURAL WORK per stamped Historic Preservation plans dated 3/9/22. No exterior work or window replacement permitted.		3/9/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
12/10/2022	3/4/2022	2022-0305	38 S. Michigan	100950582	Historic Michigan Boulevard District	42	Exterior and Interior	Exterior and Interior: SELF-CERT 2019 CBRC: INTERIOR DEMOLITION AND BUILD-OUT TO AN EXISTING GROUND FLOOR SPACE FOR A NEW GELATO SHOP AS PER PLANS IN AN EXISTING MIXED USE BUILDING. WORK TO INCLUDE NEW PARTITIONS, DOORS, HARDWARE, MILLWORK, SHELVING, CABINETRY, CEILINGS, LIGHTING, MEP FIXTURES, FINISHES, MECHANICAL, ELECTRICAL, AND PLUMBING. NO STRUCTURAL WORK. (CONSTRUCTION TYPE: 1A; EXISTING USE IS M-MERCANTILE AND PROPOSED IS A-2 ASSEMBLY). Per the Historic Preservation stamped plans dated 3/9/22. Storefront and transom glazing to be clear vision glass. Views thru the glazing into the interior space should be unobstructed. Any soffits or dropped ceilings should maintain a minimum of 24" setback from the storefront glazing.		3/9/2022
2/22/2022		2022-0306	1505 W. Jackson	100944098	Jackson Boulevard District	28	Exterior and Interior	Exterior and Interior: INTERIOR REMODEL, DECK ADDITION, NEW ROOF CONSTRUCTION, NEW ROOF HVAC UNIT INSTALLATION. Per the Historic Preservation stamped drawings dated 3/9/22. No work to the masonry, mansard roof, existing windows and front door on the front façade with this approval.		3/9/2022
3/9/2022		2022-0307	300 W. Adams	100961495	300 W. Adams St. Office Bldg	42	Miscellaneous	Electrical: REVISED LIGHTING CHANGES & VARIOUS POWER DEVICE RELOCATIONS. No other work.		3/9/2022
3/9/2022		2022-0308	200 N. LaSalle	100961642	Trustees System Service Building	42	Interior	Electrical: MONTHLY MAINTENANCE PERMIT - MARCH 2022 No other work.		3/9/2022
2/25/2022		2022-0309	330 N. Wabash	100959588	IBM Building	42	Interior	Interior: INTERIOR, NON-STRUCTURAL, ALTERATION - DEMOLITION OF THE EXISTING CONDITIONS OF THE EXISTING OFFICE SPACE ON THE 25TH FLOOR. NO NEW ELECTRICAL, MECHANICAL OR PLUMBING WORK. NO CHANGE IN USE OR OCCUPANCY. No exterior work or window replacement.		3/10/2022
2/25/2022		2022-0310	1366 E. Madison Park	100953503	Kenwood	4	Interior	Interior: SELF CERT PERMIT FOR INTERIOR ALTERATION OF EXISTING 1 STORY III-A TOWNHOUSE (ORDINARY CONSTRUCTION) WITH COURTYARD. ALTERATION INCLUDES KITCHEN REMODEL, BATHROOM REMODEL, AND NON-STRUCTURAL RECONFIGURATION OF INTERIOR PARTITIONS. NO WORK TO EXTERIOR OF BUILDING. NO CHANGE TO EXISTING OFF-STREET PARKING IN SHARED PARKING LOT. AND NO CHANGE TO SITE. No exterior work or window replacement.		3/10/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/11/2022		2022-0311	2800 N. Pine Grove	100962069	Brewster Apartments	44	Exterior	Exterior: MASONRY REPAIR AND TUCKPOINT VARIOUS LOCATIONS on roof. no work to facades. Locations indicated on the Historic Preservation stamped proposal dated 3/11/22. When grinding existing masonry joints, care shall be taken to not overcut existing masonry. New mortar shall match historic mortar in color, joint profile, texture and strength/type. Dry grinding only. No chemical cleaning or sandblasting to occur with this approval. Any water power washing shall be less than 400 psi.		3/11/2022
3/11/2022		2022-0312	2800 N. Pine Grove	Environment	Brewster Apartments	44	Environmental	Environmental: Dry grinding only. No chemical cleaning or sandblasting to occur with this approval. Any water power washing shall be less than 400 psi.		3/11/2022
3/11/2022		2022-0313	244 E. Pershing	100961687	Wendell Phillips High School	3	Miscellaneous	Misc: Installation of (1) one hydraulic passenger elevator, 3 stops, 3100LBS capacity @ 125fpm pursuant to plans submitted and subject to City of Chicago Dept. of Buildings Elevator Bureau inspection.		3/11/2022
3/1/2022		2022-0314	61 E. Van Buren	100957256	Historic Michigan Boulevard District	42	Interior	Interior: SPR 2019 - INTERIOR TENANT BUILD-OUT FOR NEW "ESCAPE ROOM" ATTRACTION per stamped Historic Preservation plans dated 3/14/22. No exterior work or storefront replacement. No opaque window film permitted.		3/14/2022
3/1/2022		2022-0315	1450 N. Astor	100959567	Astor Street District	43	Exterior	Exterior: REPLACE 6 ANTENNAS ON EXISTING CELL SITE. New antennas to be mounted no higher than existing antennas and shall be painted to match the surrounding masonry.		3/14/2022
3/3/2022		2022-0316	400 N. Michigan	100959112	Wrigley Building	42	Interior	Interior: SELF CERT 2019 CBRC: INTERIOR ALTERATIONS TO OFFICE SUITE S1020 AS PER stamped Historic Preservation plans dated 3/14/22. No exterior work or window replacement permitted.		3/14/2022
3/4/2022		2022-0317	1434 N. Astor	100940703	Astor Street District	43	Interior	Interior: INTERIOR RENOVATION AT 3 STORY MULTIFAMILY BUILDING (UNIT 2). No exterior work or window/door replacement to Astor Street elevation.		3/14/2022
3/14/2022		2022-0318	433 W. Van Buren	100962394	Old Chicago Main Post Office Building	25	Mechanical	Electrical: SECURITY SYSTEM WORK CUSU220311A - 55058 POST OFFICE UX USER ADD RM 224-227 No other work.		3/14/2022
3/14/2022		2022-0319	215 W. Eugenie	100962382	Old Town Triangle District	43	Mechanical	Electrical: 200A OH Service No other work.		3/14/2022
3/14/2022		2022-0320	224 S. Michigan	100962268	Historic Michigan Boulevard District	42	Mechanical	Electrical: SECURITY SYSTEM WORK CUSO220310A - 54326 224 S MICH S2 NETBOX REPLACE 134 No other work.		3/14/2022
3/15/2022		2022-0321	141 W. Jackson	100962470	Chicago Board of Trade Building	42	Miscellaneous	Misc: PROVIDE (19) CAT-6 CABLE RUN FOR DATA FOR SUITE # 4048		3/15/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/15/2022		2022-0322	318 N. Carpenter	100960300	Fulton-Randolph Market District	27	Miscellaneous	Misc: **FIRE ALARM PERMIT**TENANT BUILD OUT ON THE 8TH FLOOR IN AN EXISTING HIGH RISE BUILDING.		3/15/2022
3/15/2022		2022-0323	1800 S. Prairie	100962543	Glessner House Building	4	Interior	Interior: INSTALL NEW 200 AMP 3 PHASE 120-208 PANEL BOARD IN BASEMENT.INSTALL NEW 100 AMP 3 PHASE 120-208 VOLT SUBPANEL FROM NEW 200 AMP PANEL TO 3RD FLOOR.INSTALL BRANCH CIRCUITS NECESSARY TO POWER PUMPS		3/15/2022
3/15/2022		2022-0324	330 N. Wabash	100959403	IBM Building	42	Miscellaneous	Misc: SPRINT EQUIPMENT REMOVAL ONLY. NO NEW EQUIPMENT.		3/15/2022
3/15/2022		2022-0325	18 S. Michigan	100959416	Gage Group	42	Miscellaneous	Misc: REMOVE SPRINT EQUIPMENT ONLY. NO NEW EQUIPMENT.		3/15/2022
3/16/2022		2022-0326	360 N. Michigan	100910791	London Guarantee Building	42	Sign	Sign: SMASHBURGER INDOOR WINDOW DISPLAY. NO EXTERIOR SIGNAGE. NO AWNINGS PERMITTED WITH THIS PERMIT.		3/16/2022
3/16/2022		2022-0327	520 S. Michigan	100962318	Historic Michigan Boulevard District	4	Miscellaneous	Misc: monthly maintenance		3/16/2022
3/16/2022		2022-0328	448 W. Barry	Environment	Daniel Hill House	44	Environmental	Environmental: Dry grinding only. No chemical cleaning or sandblasting to occur with this approval. Any water power washing shall be less than 400 psi.		3/16/2022
3/16/2022		2022-0329	29 E. Madison	100962655	Heyworth Building	42	Mechanical	Electrical: INSTALLATION OF LOW VOLTAGE BURGLAR ALARM No other work.		3/16/2022
3/16/2022		2022-0330	1 N. State	100959824	Jewelers Row District	42	Mechanical	Electrical: **FIRE ALARM PERMIT** ** FIRE ALARM PERMIT ** INSTALLATION OF ELECTROMAGNETIC LOCKING DEVICES PER CBC SECTIONS 10(13-160-269) AND 10(13-160-260) ON FLOOR 13. No other work.		3/16/2022
3/16/2022		2022-0331	220 S. Michigan	100961886	Historic Michigan Boulevard District	42	Mechanical	Electrical: MONTHLY MAINTENANCE AND SHOW SET UPS FOR MARCH-APRIL-MAY 2022. No otherwork.		3/16/2022
3/16/2022		2022-0332	4611 N. Broadway	100954879	Uptown Square District	46	Mechanical	Electrical: **FIRE ALARM PERMIT**IN A NEW 10 STORY HIGH RISE BUILDING, BASEMENT LEVEL, FLOORS 1 THRU 9, INSTALLING A NEW HIGH RISE FIRE ALARM SYSTEM. No other work.		3/16/2022
3/16/2022		2022-0333	435 N. Michigan	100956024	Tribune Tower	42	Mechanical	Electrical: **FIRE ALARM PERMIT**TENANT BUILD OUT ON FLOORS 1 & 2 IN AN EXISTING HIGH RISE BUILDING. No other work.		3/16/2022
3/17/2022		2022-0334	3601 N. Milwaukee	100962739	Schurz High School Building	45	Miscellaneous	Misc: elevator hoist rope replacement		3/17/2022
3/17/2022		2022-0335	111 N. State	100962712	Marshall Field and Company Building	42	Miscellaneous	Misc: replace governor ropes on elevator		3/17/2022
3/17/2022		2022-0336	435 N. Michigan	100957723	Tribune Tower	42	Miscellaneous	Misc: fire alarm install		3/17/2022
3/17/2022		2022-0337	600 E. Grand	28007	Navy Pier	42	Miscellaneous	Misc: 3 Permanent Virtual Reality Amusement Riding Devices.		3/17/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/17/2022		2022-0338	19 S. Wabash	100944953	Jewelers Building	42	Sign	Sign: IWAN RIES & CO. - PROJECTING SIGN - 10'-0"H X 4'-0" PROJECTION (40 SQFT)		3/17/2022
3/17/2022		2022-0339	19 S. Wabash	100944954	Jewelers Building	42	Sign	Sign: IWAN RIES & CO - WINDOW SIGN - 1'-7"H X 4'-1"W (6 SQFT) - COPY TO READ: IWAN		3/17/2022
3/17/2022		2022-0340	19 S. Wabash	100944951	Jewelers Building	42	Sign	Sign: DIAMONDS ON WABASH - PROJECTING SIGN - 10'-0"H X 4'-0" PROJECTION (40 SQFT)		3/17/2022
3/17/2022		2022-0341	19 S. Wabash	100944956	Jewelers Building	42	Sign	Sign: IWAN RIES & CO. - WINDOW SIGN - 1'-7"H X 3'-5"W (5 SQFT) - COPY TO READ: RIES		3/17/2022
3/17/2022		2022-0342	19 S. Wabash	100944957	Jewelers Building	42	Sign	Sign: IWAN RIES & CO. - WINDOW SIGN - 1'-7"H X 2'-9"W (4 SQFT) - COPY TO READ: & CO.		3/17/2022
3/17/2022		2022-0343	300 N. State	100962697	Marina City	42	Exterior	Exterior: COMPLETE ROOF REPLACEMENT.NO WORK TO FACADES.		3/17/2022
3/17/2022		2022-0344	920 W. Randolph	100954882	Fulton-Randolph Market District	27	Sign	Sign: MOUNT SIGN TO WALL OUTSIDE OF BUILDING.		3/17/2022
3/8/2022		2022-0345	4911 S. Washington Pa	100955921	Washington Park Court District	4	Interior	Interior: REVISION TO BUILDING PERMIT #100885475. CHANGES TO FLOOR PLAN LAYOUTS. NO CHANGE IN WORK TO EXTERIOR WITH THIS REVISION.		3/17/2022
3/2/2022		2022-0346	208 S. LaSalle	100960353	Continental & Commercial National	42	Exterior	Exterior: As proposed, attachments for the new canopies and penetrations for drainage and electrical to be made on the flat vertical stone areas only. No mechanical attachments or penetrations to be made on any ornamental stone elements.	10/01/20	3/17/2022
3/17/2022		2022-0347	7415 N. Sheridan	100962605	Emil Bach House	49	Miscellaneous	Misc.: ERECTION STARTS: 4/13/2022, ERECTION ENDS: 10/10/2022. SELF CERT. 1-30'X70' SEASONAL WEDDING TENT FOR TAWANI ENTERPRISE. BLUE PEAK TENTS. No other work		3/17/2022
3/18/2022		2022-0348	1000 S. Michigan	100962767	Historic Michigan Boulevard District	4	Miscellaneous	Misc: *** HOIST PERMIT *** DUAL 10000LB RACK AND PINION ELEVATOR		3/18/2022
3/21/2022		2022-0349	7458 S. Cottage Grove	100960427	Chatham-Greater Grand Crossing	6	Exterior	Exterior: REPAIR EXISTING CHIMNEY AND PARAPET WALL ABOUT(300 SQ FT).REINSTALL EXISTING COPING,TUCKPOINTING - NO STRUCTURAL WORK - 500 SQFT.ALL WORK SAME AS EXISTING.ANY REMOVED MASONRY TO BE SALVAGED AND REINSTALLED. New mortar to match historic in color, texture, strength/type, and profile.		3/21/2022
3/21/2022		2022-0350	209 E. Lake Shore	100962910	East Lake Shore Drive District	2	Exterior	Exterior: ROOF RECOVER ONLY - NO STRUCTURAL WORK. ALL WORK SAME AS EXISTING.		3/21/2022
3/21/2022		2022-0351	851 W. Randolph	Environment	Fulton-Randolph Market District	27	Environmental	Environmental: Dry grinding only. Care to be taken not to damage surrounding masonry units. No chemical cleaning or sandblasting.		3/21/2022
3/21/2022		2022-0352	112 N. Green	Environment	Fulton-Randolph Market District	27	Environmental	Environmental: Dry grinding only. Care to be taken not to damage surrounding masonry units. No chemical cleaning or sandblasting.		3/21/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/21/2022		2022-0353	6854 S. Bennett	100937736	Jackson Park Highlands District	5	Exterior	Exterior: FENCES: 240FT IN X 6FT IN: QTY 1 SAME LOCATION AS EXISTING.		3/21/2022
3/22/2022		2022-0354	880 N. Lake Shore	100963370	860-880 N. Lake Shore Drive	2	Miscellaneous	Misc: REPLACE EXISTING FUSE PANEL WITH NEW 100 AMP BREAKERS. UNIT 17H		3/22/2022
3/22/2022		2022-0355	1119 E. 48th	100951207	Kenwood District	4	Exterior	Exterior: TUCKPOINTING - NO STRUCTURAL WORK - 100 SQFT Per the stamped description of work dated 3/22/22. Any new masonry units to match the historic units in size, shape, color, texture and finish. When grinding existing mortar joints, care shall be taken to not over-cut joints and damage existing masonry. New mortar to match historic mortar in color, joint profile, texture and strength/type. Dry grinding only. No chemical cleaning or sandblasting to occur with this approval. Any water power washing shall be less than 400 psi.		3/22/2022
3/22/2022		2022-0356	1119 E. 48th	Environment	Kenwood District	4	Environmental	Environmental: For associated permit application #100951207. When grinding existing mortar joints, care shall be taken to not over-cut joints and damage existing masonry. New mortar to match historic mortar in color, joint profile, texture and strength/type. Dry grinding only. No chemical cleaning or sandblasting to occur with this approval. Any water power washing shall be less than 400 psi.		3/22/2022
3/22/2022		2022-0357	244 E. Pershing	100951181	Wendell Phillips High School	3	Exterior	Exterior: TUCKPOINTING - NO STRUCTURAL WORK - 100 SQFT Per the stamped description of work dated 3/22/22. Any new masonry units to match the historic units in size, shape, color, texture and finish. When grinding existing mortar joints, care shall be taken to not over-cut joints and damage existing masonry. New mortar to match historic mortar in color, joint profile, texture and strength/type. Dry grinding only. No chemical cleaning or sandblasting to occur with this approval. Any water power washing shall be less than 400 psi.		3/22/2022
3/22/2022		2022-0358	244 E. Pershing	Environment	Wendell Phillips High School	3	Environmental	Environmental: For associated permit application #100951181. When grinding existing mortar joints, care shall be taken to not over-cut joints and damage existing masonry. New mortar to match historic mortar in color, joint profile, texture and strength/type. Dry grinding only. No chemical cleaning or sandblasting to occur with this approval. Any water power washing shall be less than 400 psi.		3/22/2022
3/22/2022		2022-0360	1 N. State	100959771	Jewelers Row District	42	Mechanical	Electrical: **FIRE ALARM PERMIT**ADDING NEW FIRE ALARM RELAY ON THE 13TH FLOOR FOR TENANT DOOR RELEASE No other work.		3/22/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/23/2022		2022-0361	141 W. Jackson	100959147	Chicago Board of Trade Building	42	Miscellaneous	Misc: **FIRE ALARM PERMIT**EXPAND EXISTING CITY OF CHICAGO APPROVED NOTIFIER NFS2-303 VOICE SYSTEM TO ACCOMMODATE A BUILD OUT ON THE 20TH FLOOR		3/23/2022
3/23/2022		2022-0362	536 W. Cermak	100963611	Cermak Road Bridge District	25	Miscellaneous	Misc: Decommission of One(1) 4000LB Capacity, 9-Floor, 150FPM, Freight Elevator(Southeast), pursuant to the scope of work submitted.(EV000860)		3/23/2022
3/23/2022		2022-0363	5000 S. Woodlawn	100963359	Kenwood	4	Exterior	Exterior: REMOVE & REPLACE 55 LINTELS (ALL BELOW 6')AND TUCKPOINT WHERE NEEDED. APPROX.1500SQFT. ANY REMOVED MASONRY TO BE SALVAGED AND REINSTALLED. NEW MORTAR TO MATCH HISTORIC IN COLOR, TEXTURE, STRENGTH/TYPE, AND PROFILE.		3/23/2022
3/23/2022		2022-0364	1800 S. Prairie	100961508	Glessner House Building	3	Exterior	Exterior: MASON REPAIRS INCLUDES TUCKPOINTING,GRINDING ON NORTHEAST AND SOUTHEAST CORNERS(200 SQ FT)MASON CHIMNEY(20 SQ FT)REPLACE SEALANT AT NORTH AND SOUTH COPING(90LF),AND SOUTH FACADE STUCCO(45 LF). Per the stamped exhibits dated 3/23/22. Any new masonry units to match the historic units in size, shape, color, texture and finish. When grinding existing mortar joints, care shall be taken to not over-cut joints and damage existing masonry. New mortar to match historic mortar in color, joint profile, texture and strength/type. Dry grinding only. No chemical cleaning or sandblasting to occur with this approval. Any water power washing shall be less than 400 psi.		3/23/2022
3/23/2022		2022-0365	1800 S. Prairie	Environment	Glessner House Building	3	Exterior	Environmental: Dry grinding only. No chemical cleaning or sandblasting to occur with this approval. Any water power washing shall be less than 400 psi. For associated Permit #100961508.		3/23/2022
3/23/2022		2022-0366	332 S. michigan	100963605	Historic Michigan Boulevard District	42	Mechanical	Electrical: **FIRE ALARM PERMIT**FIRE ALARM PERMIT* * FIRE ALARM PERMIT* MODIFICATION OF AN EXISTING, CHICAGO APPROVED HIGH RISE (PER 907.2.12 HIGH-RISE BUILDINGS) VOICE EVACUATION/FIRE ALARM SYSTEM TO ACCOMMODATE TENANT RENOVATION. BUILDING IS FULLY SPRINKLERED. No other work.		3/23/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
11/3/2021	3/11/2022	2022-0367	1954 W. North	100946655	Milwaukee Avenue District	2	Exterior and Interior	Interior and Exterior: DDS 2019 CBRC: INTERIOR AND EXTERIOR RENOVATION TO EXISTING 4 STORY WITH BASEMENT COMMERCIAL BUILDING, 9 UNIT RESIDENTIAL APARTMENT ON FLOORS 2-4 AND GROUND FLOOR RETAIL SPACE. WORK TO INCLUDE NEW TURRET ADDITION AT SW CORNER, NEW AMENITY ROOFTOP TERRACE, NEW ELEVATOR & STAIR CORE TO ROOF TERRACE, NEW STOREFRONT , FACADE RENOVATION WITH NEW METAL CORNICE, WINDOW REPAIRS/REPLACEMENT AS NEEDED AS PER stamped Historic Preservation plans dated 3/24/22. All new masonry to match historic in size, color, texture and general appearance. New mortar to match historic in color, texture, strength/type, and profile. New masonry samples to be reviewed by Historic Preservation staff prior to order and installation.		3/24/2022
12/21/2022	3/9/2022	2022-0368	2053 W. Evergreen	100944839	Wicker Park District	1	Exterior and Interior	Exterior and Interior: SPR 2019 CBRC: INTERIOR RENOVATIONS & DUPLEX DOWN (3) D.U. ON 3-STORY BRICK BUILDING WITH BASEMENT, NEW ROOFTOP DECK AND REPL. ENCL. FRAME PORCH WITH REAR METAL PORCH, PER PLANS. Per the Historic Preservation stamped drawings dated 3/24/22. As proposed, the existing windows on the front facade are to remain. No work to the front facade with this approval.		3/24/2022
2/9/2022	3/8/2022	2022-0369	1001 W. Armitage	100957987	Armitage-Halsted District	43	Exterior and Interior	Exterior and Interior: RENOVATION OF AN EXISTING STARBUCKS COFFEE. SCOPE TO INCLUDE:NEW INTERIOR PARTITIONS, EQUIPMENT, FIXTURES, & FINISHES. ALL SIGNAGE UNDER SEPARATE PERMIT AS PER PLANS. Per the Historic Preservation stamped drawings dated 3/24/22. The existing masonry facade shall not be painted. Signs are not approved with this permit. Each sign will require a separate sign permit application for review and approval.		3/24/2022
3/24/2022		2022-0370	2014 W. Walton	100963209	Ukrainian Village District	0	Interior	Interior: REPAIR/REPLACE (2594 SF) OF DRYWALL,REMOVE PLASTER AND LATHE FLOORING. No exterior work. Per the stamped letter of intent of work dated 3/24/22.		3/24/2022
3/24/2022		2022-0371	7 W. Madison	100963938	Chicago Building	42	Mechanical	Electrical: DISCONNECT POWER TO EXISTING ROOFTOP UNIT. RECONNECT POWER TO NEW UNIT. No other work.		3/24/2022
3/25/2022		2022-0372	47 E. Division	100962832	Astor Street District	2	Exterior	Exterior: GUTTER REPLACEMENT,ROOF MAINTENANCE,REPAIRS AND ROOF TING O (3)STORY SINGLE FAMILY.		3/25/2022
3/25/2022		2022-0373	209 S. Lasalle	Environment	Rookery Building	42	Environmental	Environmental: Dry grinding only. Care to be taken not to damage surrounding masonry units. No chemical cleaning or sandblasting permitted.		3/25/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/15/2022		2022-0374	2 N. Michigan	100956436	Historic Michigan Boulevard District	42	Exterior and Interior	Interior and Exterior: EXISTING USE 17-17-0104-K EATING AND DRINKING ESTABLISHMENT. NO CHANGE IN USE. SCOPE OF WORK TO INCLUDE: INTERIOR FIRST FLOOR BUILD OUT FOR FAST CASUAL CLASS A-2 RESTAURANT, INCLUDING MEP'S IN EXISTING 1-A MIXED-USE BUILDING. AREA OF WORK 5,100 SF per stamped Historic Preservation plans dated 3/25/22. New marble bulkhead to match historic in size, color, texture, and general appearance. New louver vent (1) to match finish of existing storefronts. No signage approved with this permit.		3/25/2022
2/7/2022	3/16/2022	2022-0375	860 N. Lake Shore	100951303	860-880 N. Lake Shore Drive	2	Interior	Interior: SPR 2019 CBC. INTERIOR REMODELING TO EXISTING APARTMENT 4M. ALL WORK AS PER stamped Historic Preservation plans dated 3/25/22. New air conditioning units to not extend past glazing line.		3/25/2022
3/25/2022		2022-0376	884 N. Hermitage	100958969	East Village District	1	Interior	Interior: RELOCATE LAUNDRY AND ASSOCIATED PIPING. INSTALL VENT IN KITCHEN. No other work.		3/25/2022
3/25/2022		2022-0377	81 E. Van Buren	100964141	Historic Michigan Boulevard District	42	Miscellaneous	Misc.: ERECT TWO (2) SCAFFOLDS. DATES 03/25/2022 THROUGH 03/25/2023 No other work.		3/25/2022
3/25/2022		2022-0378	6734 S. Constance	100964033	Jackson Park Highlands District	5	Mechanical	Misc.: REVISION TO CHANGE OF PLUMBING CONTRACTORS TO ARTANDAS PLUMBERING,HVAC CONTRACTOR TO DORADO HEATING & COOLING PERMIT#100928250		3/25/2022
3/25/2022		2022-0379	332 S. Michigan	100964117	Historic Michigan Boulevard District	42	Mechanical	Electrical: CARD READER AND VIDEO SYSTEM. interior only.		3/25/2022
1/4/2022	3/13/2022	2022-0380	2901 W. Logan	100951350	Logan Square Boulevards District	32	Exterior and Interior	Exterior and Interior: SELF CERT 2019: INTERIOR ALTERATIONS TO EXISTING 1ST FLOOR AND BASEMENT OF A 3 STORY BUILDING AS PER PLANS. UNITS WILL BE COMBINED. NO EXTERIOR WORK. NO CHANGE IN USE, R5-RESIDENTIAL. CONSTRUCTION TYPE 3A Per the Historic Preservation stamped drawings dated 3/25/22. The existing leaded glass windows located in the transoms on the 1st, 2nd and 3rd floor bays are to remain with new fixed windows to be installed below to match the size and configuration of the existing windows. All other windows to be double-hung. As proposed, the new windows to be clad-wood. No work to the masonry to occur on any façade.		3/28/2022
3/28/2022		2022-0381	220 E. Chicago	100962651	Old Chicago Water Tower District	2	Mechanical	Electrical: MAINTENANCE FOR APRIL 2022 No other work.		3/28/2022
3/28/2022		2022-0382	350 E. Cermak	100962652	R.R. Donnelley Plant	27	Mechanical	Electrical: MAINTENANCE FOR APRIL 2022 No other work.		3/28/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/28/2022		2022-0383	350 E. Cermak	100962653	R.R. Donnelley Plant	27	Mechanical	Electrical: LOW VOLTAGE CABLING FOR APRIL 2022 No other work.		3/28/2022
3/28/2022		2022-0384	160 N. Peoria	100963949	Fulton-Randolph Market District	27	Mechanical	Electrical: PROVIDE TEMP CIRCUITRY FOR POWER AND LIGHTS No other work.		3/28/2022
3/28/2022		2022-0385	1342 N. Hoyne	100964457	Wicker Park District	2	Mechanical	Electrical: **ELECTRICAL ONLY PERMIT**UPGRADE ELECTRICAL SERVICE FROM 400 AMPS TO 600 AMPS. EXISTING PERMIT NUMBER IS 100815027. No other work.		3/28/2022
3/29/2022		2022-0386	531 S. Plymouth	100963219	Printing House Row District	4	Exterior	Exterior: WEST PARAPET, RESET SHIFTED BRICKS 200SQFT. ALL WORK SAME AS EXISTING. ALL MASONRY REMOVED TO BE SALVAGED AND REINSTALLED WITH ANY DETAILING REPLICATED IN KIND.		3/29/2022
3/29/2022		2022-0387	1250 N. Astor	100963947	Astor Street District	43	Exterior	Exterior: TUCKPOINTING - NO STRUCTURAL WORK - 500 SQFT. Care to be taken not to damage surrounding masonry units. All new mortar to match historic in color, texture, strength/type, and profile.		3/29/2022
3/29/2022		2022-0388	18 S. Michigan	100963889	Gage Group	42	Exterior	Exterior: COMPLETE FLAT ROOF REPLACEMENT.		3/29/2022
3/29/2022		2022-0389	2133 N. Hudson	100963895	Mid-North District	43	Exterior	Exterior: COMPLETE FLAT ROOF REPLACEMENT.		3/29/2022
3/29/2022		2022-0390	2150 N. Cleveland	100963913	Mid-North District	43	Exterior	Exterior: FLAT ROOF RECOVER ONLY - NO STRUCTURAL WORK, TUCKPOINTING - NO STRUCTURAL WORK - 1 SQFT		3/29/2022
3/25/2022		2022-0391	932 W. Randolph	100960177	Fulton-Randolph Market District	27	Interior	Interior: Per the Historic Preservation stamped drawings dated 3/29/22. No exterior work or alterations to the existing windows and storefronts with this approval.		3/29/2022
3/29/2022		2022-0392	1003 W. Armitage	100964423	Armitage-Halsted District	43	Exterior	Exterior: COMPLETE ROOF TEAR OFF - FLAT ROOF		3/29/2022
3/29/2022		2022-0393	120 W. Adams	100940288	Field Building	42	Sign	Sign: (1) 4'-9" X 11'-3 1/4" COVER UP ON SOUTH ELEVATION. NO WORK TO HISTORIC STONE per stamped exhibit dated 3/29/22.		3/29/2022
3/29/2022		2022-0394	2150 N. Cleveland	Environment	Mid-North District	43	Environmental	Environmental: Dry grinding only. Care to be taken not to damage surrounding masonry units. No sandblasting or chemical cleaning.		3/29/2022
3/8/2022	3/28/2022	2022-0395	1060 W. Addison	100959644	Wrigley Field	44	Exterior	Exterior: ***DIRECT DEVELOPER SERVICES*** CONCOURSE IMPROVEMENTS ON EXISTING 100 LEVEL OF WRIGLEY FIELD. WORK TO INCLUDED SELECT DEMO & CONSTRUCTION OF NEW PARTITIONS, FINISHES, & PLUMBING; AS PER PLANS. CONSULTANT REVIEWER: GLOBETROTTERS ENGINEERING Per the Historic Preservation stamped drawings dated 3/29/22. Removed terra cotta tiles and ornamental grilles/gates shall be carefully removed, salvaged and stored for future reinstallation.	08/05/21	3/29/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
12/29/2021	3/14/2022	2022-0396	2014 W. Walton	100951102	Ukrainian Village District	2	Exterior and Interior	Exterior and Interior: SPR 2019 CBRC: RENOVATION OF EXISTING HOUSE, REAR ADDITION AND NEW GARAGE.(OCCUPANCY CLASS R-5, CONSTRUCTION TYPE IIIA) Per the Historic Preservation stamped drawings dated 3/29/22. As proposed, the new dormer will be constructed to be no higher or wider than the existing dormer located directly in front of it. Skylight installation per the submitted details and frame color to match the color of the roof shingles to reduce visibility.		3/29/2022
2/24/2022	3/16/2022	2022-0397	2127 W. Le Moyne	100955614	Wicker Park District	1	Exterior and Interior	Interior and Exterior: CONVERT AN EXISTING TWO UNIT BUILDING INTO A SINGLE FAMILY RESIDENCE. INTERIOR RENOVATION AND ADDITION TO AN EXISTING TWO STORY PLUS BASEMENT MASONRY BUILDING per stamped Historic Preservation plans dated 3/30/22. All stained glass to be retained and reinstalled. New windows to be aluminum clad wood matching the historic configurations. No chemical cleaning.		3/30/2022
3/30/2022		2022-0398	1928 N. Lincoln	100961749	Lincoln Avenue Rowhouses	43	Interior	Interior: INTERIOR PAINTING, FLOORING, AND TILE WORK. NO EXTERIOR WORK OR WINDOW REPLACEMENT PERMITTED.		3/30/2022
3/16/2022		2022-0399	3100 W. Logan	100951388	Logan Square Boulevards District	32	Exterior	Exterior: RENOVATIONS TO FRONT EXTERIOR PORTION OF 2 STORY BRICK BUILDING WITH BASEMENT. REMOVE AND REPLACE FLOOR TO FRONT SECOND-STORY BALCONY SAME AS EXISTING AS PER PLANS. NO REMOVAL OF STONE BALCONY ELEMENTS OR BALUSTRADES.		3/30/2022
3/30/2022		2022-0400	330 N. Wabash	100964717	IBM Building	42	Miscellaneous	Misc: Replacement of Hoist Cables on One(1) 4000LB Capacity, 14-Floor, 500FPM, Passenger Elevator(#2), pursuant to the scope of work submitted.(EV006988)		3/30/2022
3/30/2022		2022-0401	140 E. Walton	100964783	East Lake Shore Drive District	2	Miscellaneous	Misc: Replacement of Suspension Traction Media(STM) on One(1) 3000LB Capacity, 12-Floor, 450FPM, Passenger Elevator(CAR #4), pursuant to the scope of work submitted.(EV007229)		3/30/2022
3/13/2022		2022-0402	932 W. Randolph	100962119	Fulton-Randolph Market District	27	Interior	Interior: [SELF-CERT PROJECT: NO CHANGE IN USE] ALTERATIONS/RENOVATIONS TO AN EXISTING MERCANTILE/RETAIL TENANT SPACE ON THE FIRST FLOOR, AS PER PLANS (LULULEMON). Per the Historic Preservation stamped drawings dated 3/30/22. As proposed, temporary graphics will be applied on the windows and will be removed prior to store opening. Any tenant branded signs to remain are required to have separate permit applications for each sign for review and approval.		3/30/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
3/30/2022		2022-0403	203 N. Wabash	100964742	Old Dearborn Bank Building	42	Scaffold	Scaffold: ERECT TWO (2) SCAFFOLDS DATES 03/30/2022 THROUGH 03/30/2023 No other work.		3/30/2022
3/30/2022		2022-0404	307 N. Michigan	100964730	Old Republic Building	42	Mechanical	Electrical: LOW VOLTAGE A/V INSTALLATION ON 2ND FLOOR FOR OLD REPUBLIC. No other work.		3/30/2022
3/31/2022		2022-0405	1372 N. Milwaukee	100964965	Milwaukee Avenue District	1	Exterior	Exterior: REPLACE TWO ROOFTOP UNITS WITH TWO 40 TON, AIR COOLED, SELF-CONTAINED, R410A, YORK ROOFTOP UNITS, SERVING A COMMERCIAL SPACE. SAME LOCATION		3/31/2022
3/31/2022		2022-0406	81 E. Van Buren	100964611	Historic Michigan Boulevard District	42	Exterior	Exterior: MASONRY REPAIRS TO THE CHICAGO CLUB:POINT(4800 SQFT)INSTALL PERIMETER SEALANT AROUND WINDOWS(100 LF).		3/31/2022
3/31/2022		2022-0407	81 E. Van Buren	Environment	Historic Michigan Boulevard District	42	Environmental	Environmental: Dry grinding only. Care to be taken not to damage surrounding masonry units. New mortar to match historic in color, texture, strength/type, and profile. No sandblasting or chemical cleaning permitted.		3/31/2022
3/31/2022		2022-0408	1372 N. Milwaukee	100964978	Wicker Park District	1	Exterior	Exterior: REPLACE (2) ROOF TOP UNITS SAME SIZE AND LOCATION.		3/31/2022
3/31/2022		2022-0409	903 W. Armitage	100925736	Armitage-Halsted District	43	Sign	Sign: INSTALL ONE (1) LED ILLUMINATED CHANNEL LETTER SET ON NORTH ELEVATION OF BUILDING Per the Historic Preservation stamped exhibits dated 3/31/22. As proposed, new sign to be installed on siding above storefront. No part of the sign shall be attached to or obscure the historic cast iron columns.		3/31/2022
3/31/2022		2022-0410	903 W. Armitage	100931242	Armitage-Halsted District	43	Sign	Sign: INSTALL ONE (1) LED ILLUMINATED DOUBLE FACE BLADE SIGN ON NORTH ELEVATION OF BUILDING Per the Historic Preservation stamped exhibits dated 3/31/22. As proposed, new sign to be installed on siding above storefront. No part of the sign shall be attached to or obscure the historic cast iron columns.		3/31/2022
3/18/2022		2022-0411	209 S. Lasalle	100962074	Rookery Building	42	Interior	Interior: SELF-CERT 2019 CBC: INTERIOR ALTERATIONS TO OFFICE SUITE 625. WORK INCLUDES ARCHITECTURAL, MECHANICAL, ELECTRICAL, PLUMBING AND FIRE PREVENTION AS PER stamped Historic Preservation plans dated 3/31/22. No exterior work or window replacement.		3/31/2022
3/31/2022		2022-0412	5016 S. Greenwood	100961135	Kenwood	4	Exterior	Exterior: ERRECT(6 X 237)FENCE. Per the Historic Preservation stamped site plan dated 3/31/22. Proposed open ornamental metal fence is approved. No part of the fence or gate to be installed past the face of the front façade.		3/31/2022

Date Rcv'd	Correct'd	Rev #	Address	Permit#	Landmark/District	Ward	Work	Conditions of Approval	PRC Date	Date
11/29/2021	3/31/2022	2022-0413	1132 N. Winchester	100946974	East Village District	2	Exterior and Interior	Exterior and Interior: SPR 2019 CBC. DECONVERSION 3 DU TO 2 DU AND INTERIOR RENOVATION WITH NEW THIRD FLOOR FRAME ADDITION IN EXISTING MASONRY BUILDING. ALL WORK AS PER stamped Historic Preservation plans dated 3/31/22. Any new brick mortar required to match historic in color, texture, strength/type, and profile. Materials to match those in 4/21 PRC submittal package.		3/31/2022
3/31/2022		2022-0414	209 S. Lasalle	100965113	Rookery Building	42	Scaffold	Scaffold: ERECT ONE (1) SCAFFOLD DATES 04/01/2022 THROUGH 04/01/2023		3/31/2022
3/31/2022		2022-0415	600 E. Grand	100964944	Navy Pier	42	Mechanical	Electrical: APRIL 2022 ELECTRICAL MAINTENANCE		3/31/2022
3/31/2022		2022-0416	330 N. Wabash	100956385	IBM Building	42	Sign	Sign: FABRICATE AND INSTALL ONE (1) INTERNALLY ILLUMINATED INDIVIDUAL LETTERSET MOUNTED TO THE SOUTH WALL OF PROPERTY FACING THE CHICAGO RIVER READING "THE LANGHAM CHICAGO" (91735_LL-02_J04_THE_LANGHAM_CHICAGO_IL). Per the Historic Preservation stamped exhibits dated 3/31/22. Attachment locations to be located in mortar joints.		3/31/2022
3/31/2022		2022-0417	2136 N. Cleveland	100964689	Mid-North District	43	Demolition: Garage	Demolition Garage: WRECK AND REMOVE A FRAME RESIDENTIAL GARAGE. Per the Historic Preservation stamped exhibits dated 3/31/22. No work to the main house to occur with this approval.		3/31/2022
3/31/2022		2022-0418	1215 E. Madison Park	100963143	Kenwood	4	Exterior	Exterior: TUCKPOINTING - NO STRUCTURAL WORK - 600 SQFT AND BRICK REPLACEMENT Per the Historic Preservation stamped exhibits dated 3/31/22. When grinding existing mortar joints, care shall be taken to not overcut joints and damage existing masonry. New mortar shall match historic in color, joint profile, texture and strength/type. Any new brick or limestone units to match the historic in material, size, shape, color, texture and finish. Masonry pressure washing shall not exceed 400 psi. Dry grinding only. No chemical cleaning or sandblasting to occur with this approval.		3/31/2022
3/31/2022		2022-0419	1215 E. Madison Park	Environment	Kenwood	4	Environmental	Environmental: Per the associated permit #100963143. Dry grinding only. No chemical cleaning or sandblasting to occur with this approval.		3/31/2022

Date Rcv'd Correct'd Rev # Address Permit# Landmark/District Ward Work Conditions of Approval PRC Date Date

TOTAL # OF PERMIT APPLICATIONS APPROVED: 160
TOTAL # OF REVIEWS PERFORMED: 183
AVERAGE # OF DAYS TO ISSUE CORRECTIONS/APPROVAL 3.4